

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1574:135

Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: ADT Security Services, Inc, 695 US Highway 46, Suite 200, Fairfield NJ 07004-1561
Contact: Ron Dalton (310) 752-2472 FAX (310) 752-2942

DESIGN: Model ADT-3501 Notification Appliance Circuit (NAC) Power Extender. Refer to listee's data sheet for detailed product description and operational considerations. Unit components:

ADT-3551
ADT-3552

NAC Option Card
Class A Adaptor

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a NAC power extender unit for use with listee's separately listed fire alarm control units. Refer to listee's Installation Instruction Manual for details.

NOTE: For fire alarm use, the secondary (standby) power supply shall supply energy during power loss to operate a protected premises, central station, or proprietary system for 24 hours or an auxilliary or remote station system for 60 hours in the normal condition followed by not less than 5 minutes of alarm as required by code.

XLF: 7300-0026:214

0213-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

FEBRUARY 13, 2004

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager